



Calaveras County

Environmental Management Agency

Brad Banner ♦ Agency Administrator / Director of Environmental Health / Air Pollution Control Officer

February 27, 2018

Lakeside Mobile Estates
Attn: Bonnie K. Tuckerman
P.O. Box 623
Railroad Flat, CA 95248

Re: Notice of Violation: Total Coliform/E.Coli MCL, January 2018

Dear Bonnie K. Tuckerman,

Water purveyors (pursuant to Article 3, Section 64421(a)(2), Title 22 of the California Health and Safety Code) are required to conduct periodic water tests for Total Coliform Bacteria.

Our records indicate that the Water System at Lakeside Mobile Estates has incurred a Total Coliform/E.Coli MCL violation during the month of January 2018.

A Level 2 Assessment was completed and it appears the reason for the positive samples was due to a line break/repair. Please note that all repairs must be made in accordance with the American Water Works Association, to prevent any further repairs, positive test results, or complications that may incur.

Lakeside must collect 5 bacteriological samples from the distribution system for the month of February, due to the fact there are less than 5 samples per month collected, and there was a positive test last month.

If you have questions regarding these requirements, please free to contact me. I can be reached at the office at (209) 754-6887.

Sincerely,

Stephanie Hessler, EHST
Drinking Water Program

cc: Lisa Medina, Manager, Environmental Health Department

Government Center, 891 Mountain Ranch Road, San Andreas, CA 95249-9709

♦ Environmental Health Department	♦ Onsite Wastewater Department	♦ Air Pollution Control District	♦ Animal Services	♦ Department of Agriculture & Weights and Measures
(209) 754-6399 Ext. 1	(209) 754-6400	(209) 754-6399 Ext. 4	(209) 754-6509	(209) 754-6504
(209) 754-6722 Fax	(209) 754-6722 Fax	(209) 754-6722 Fax	(209) 754-6815 Fax	(209) 754-9256 Fax